

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sub Divisional Level Water Quality Testing Laboratory

(Name of Officers with designation) from Technical Manager (Sub Divi. PHED Uttarakhand Jal Sansthan

inspected the Principal Atal Uttaraksh Govt. Inter College, Aarkot

(Name & Address of the school) on 10/05/2028 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 03/UJL/SDLWQTM/13/05/2028 dated 13/05/2028

of Sub Divisional Level W.Q.T.M.L. Barkot (PHED Lab) certified that

the Principal Atal Uttaraksh Govt. Inter College, Aarkot, Teh. mori. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31.03.2029

Signature with Seal: Executive Engineer
Name Maintenance Division
Designation Uttarakhand Jal Sansthan
Name & Address of the Office / Department Purora

To Principal,
Atal Uttaraksh Govt. Inter College Aarkot
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Badkot
E-mail: ujspurola@gmail.com

Test Report ID: 03/UJS/SDLWQTML/2026-2027

Dated: 13/05/2026

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Principal Atal Utkrith Government Inter College, Arakot		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from GIC Arakot
Reference Sample Identification:	SDWQTML/UJS/GIC/Arakot-03		Date of Start of Analysis: 11/05/2026 Date of End of Analysis: 12/05/2026
Date and Time of Sample Received: 11/05/26 & 01:00 PM	Sample Collected by:		Vinod Bartwal

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (IS10500: 2012)	Permissible Limit (IS10500:2012) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.99	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 2022 Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	256	500	2000	IS 3025 (Part 16), 2023 Gravimetric Method
3.	Turbidity, NTU, Max	0.55	1	5	IS 3025 (Part 10), 2023 Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	46	200	600	IS 3025 (Part 23), 2023, Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	91	200	600	IS 3025 (Part 21), 2009 RA:2019, EDTA Titrimetric Method
6.	Chloride, mg/L, Max	23.99	250	1000	IS 3025 (Part 32), 2019 Argentometric Method
7.	Color, Hazen, Max	5	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
8.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
9.	Calcium (as Ca), mg/L, Max	23.2	75	200	IS 3025 (Part 40), 2023 EDTA Titrimetric Method
10.	Magnesium (as Mg), mg/L, Max	8.01	30	100	APHA 24 th -3500-Mg Method B: 2023 Calculation method
11.	Total Coliform Bacteria	Absent	Absent	Absent	MPN/100(ml)
12.	E.Coli Bacteria	Absent	Absent	Absent	MPN/100(ml)

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Technical Manager
Sub Divisional Level
WQTM-LAB

-End of Report-

Uttarakhand Jal Sansthan

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of testing laboratory.